

Air conditioning inspection certificate

Courtauld Institute of Art
Somerset House, Strand
LONDON
WC2R 0RN

Certificate number
1047-4364-0002-0296-0006

Valid until
9 June 2029

Assessment details

Inspection date	10 June 2024
Inspection level	Level 4
Assessment software	Sterling Accreditation, Sterling e-Volve, v1.2
Assessor's declaration	Not related to the owner/occupier or person who has technical control of the system or subcontractor.
F-Gas compliant date	Not Provided
Total effective rated output	261 kW
System sampling	Yes
Treated floor area	5,300 square metres
Subsystems metered	Yes
Total estimated refrigerant charge	31 kg

Inspection report

For the assessor's recommendations, [see the inspection report \(/energy-certificate/2490-5826-3040-0108-0095\)](#).

Subsystems inspected

Subsystem ID	Description	Refrigerant type	Age of main components
VOL001/SYS001 SYS001	Main Gallery Cooling System	R407C	2019
VOL001/SYS002 SYS002	Security Room and IT Room Cooling	R410A	2013

Assessor's details

Assessor's name	Stephen J Hill
Email	steve.hill@encred.co.uk
Assessor ID	LCEA059466
Employer/Trading name	
Employer/Trading address	23 Austin Friars, EC2N 2QP
Accreditation scheme	CIBSE Certification Limited
Accreditation scheme telephone	020 8772 3649
Accreditation scheme email	epc@cibsecertification.org